

CERTIFICATE

of conformity with the following European Directives

Low Voltage Directive 2014/35/EU

This certifies that below described products of the applicant:

NINGBO AUSTA SOLAR TECH CO., LTD.

1-1, NO.136, Haichuan Road, Jiangbei District, Ningbo, Zhejiang,
P.R. China

comply to the essential requirements of the above mentioned European Directive and the following standards, taking into account the German national deviations:

Product(s): Grid Tie Solar Inverter

Model type(s): AU3K1P, AU4K1P, AU5K1P, AU6K1P, AU8K1P, AU10K1P

This certificate of conformity is based on the evaluation of samples of the product. It does not imply an assessment of the production and it does not permit the use of a mark of conformity or of a safety mark of the TÜV NORD CERT GmbH. The holder of this certificate may use this Certificate together with his EC-Declaration of Conformity.

Certification program: P33-VA-01 Rev. 02 / 04.20
Certification fundamental(s): EN 62109-1:2010; EN 62109-2:2011
Registered no.: 44 799 24 406749 - 141
Report no.: 492013098.001
File no.: PVP12091/23E-04



TÜV NORD CERT GmbH
Certification Body
Balance of System (BOS) for Photovoltaics

Essen, 2024-04-22

TÜV NORD CERT GmbH

Am TÜV 1, D-45307 Essen

www.tuev-nord-cert.de

prodcert@tuev-nord.de

Please also pay attention to the information stated overleaf.



The CE marking may be affixed on the product if all relevant and effective Directives are complied with.



ANNEX

Annex 1, Page 1 of 2

to Certificate registration no. 44 799 24 406749 - 141

Description of product(s):

Model or Type designation	AU3K1P	AU4K1P	AU5K1P	AU6K1P	AU8K1P	AU10K1P
PV input parameters:						
V _{MAX} PV [Vd.c.]	550					
MPP Voltage Range [Vd.c.]	80-550					
Max. PV Input Current [Ad.c.]	18	18/18	18/18	18/18	20/26	20/30
DC Short-circuit current [Ad.c.]	22.5	22.5/22.5	22.5/22.5	22.5/22.5	25/32.5	25/37.5
AC output (Grid Side) parameters:						
Rated Output Voltage [Va.c.]	220/230, L/N/PE					
Rated Output Frequency [Hz]	50/60					
Max. Output Current [Aa.c.]	15	20	25	27.3	36.4	45.5
Max. output Power [W]	3300	4400	5500	6600	8800	11000



ANNEX

Annex 1, Page 2 of 2

to Certificate registration no. 44 799 24 406749 - 141

Max. Apparent Power [VA]	3300	4400	5500	6600	8800	11000
Power Factor $\cos\phi$ [λ].....	0.8 leading to 0.8 lagging					
Others:						
Protective class.....	Class I					
Inverter topology.....	Non-isolated					
Operation temperature range.....	-25~60°C					
Ingress protection.....	IP66					
Overvoltage-category.....	OVC II(PV), OVC III(AC)					
Dimensions, D*W*H (mm)	347*368*167			347*368*190		
Weight (kg)	10			11		
Permissible Altitude (m)	2000					
Software.....	CPU1: V1.0, CPU2: V1.0					

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 3 of test report.



TÜV NORD CERT GmbH
 Certification Body
 Balance of System (BOS) for Photovoltaics

Essen, 2024-04-22